

**PRIORITY AREAS LEAD TESTING AND CORRECTIVE ACTIONS (OCTOBER 2014)**  
**PMRF CHILD DEVELOPMENT CENTER**  
**BUILDING 1283**

**Table 1. Summary of Results**

| SAMPLING LOCATION DESCRIPTION |          |                    | INITIAL SAMPLING RESULTS   |                  |                       | COMMENTS |
|-------------------------------|----------|--------------------|----------------------------|------------------|-----------------------|----------|
|                               |          |                    | Recommended Level = 20 ppb |                  |                       |          |
| SAMPLE ID                     | ROOM NO. | Outlet Description | First Draw (ppb)           | Retest Required? | Date Fixture Secured? |          |
| <b>SAMPLING DATE</b>          |          |                    | 10/15/2014                 |                  |                       |          |
| <b>RESULTS DATE</b>           |          |                    | 11/3/2014                  |                  |                       |          |
| PMRF-1283-K-K-FD              | 2        | Kitchen Sink       | <0.5                       | No               | N/A                   |          |
| PMRF-1283-K-ICE-FD            | 2        | Ice Machine        | <0.5                       | No               | N/A                   |          |
| PMRF-1283-LOUNGE-HHW-FD       | 5        | Adult Sink         | <0.5                       | No               | N/A                   |          |

PRIORITY AREAS LEAD TESTING AND CORRECTIVE ACTIONS (OCTOBER 2014)  
 PMRF INFANT CARE CENTER  
 BUILDING 1284

Table 1. Summary of Results

| SAMPLING LOCATION DESCRIPTION |                    |                    | INITIAL SAMPLING RESULTS   |                  |                       | COMMENTS |
|-------------------------------|--------------------|--------------------|----------------------------|------------------|-----------------------|----------|
| SAMPLE ID                     | ROOM NO.           | Outlet Description | Recommended Level = 20 ppb |                  |                       |          |
|                               |                    |                    | First Draw (ppb)           | Retest Required? | Date Fixture Secured? |          |
| <b>SAMPLING DATE</b>          |                    |                    | 10/15/2014                 |                  |                       |          |
| <b>RESULTS DATE</b>           |                    |                    | 11/3/2014                  |                  |                       |          |
| PMRF-1284-DCA-HHW(A)-FD       | Diaper Change Area | Adult Sink         | <0.5                       | No               | N/A                   |          |
| PMRF-1284-DCA-HHW(B)-FD       | Diaper Change Area | Adult Sink         | <0.5                       | No               | N/A                   |          |

PRIORITY AREAS LEAD TESTING AND CORRECTIVE ACTIONS (OCTOBER 2014)  
 PMRF YOUTH CARE CENTER  
 BUILDING 1318

Table 1. Summary of Results

| SAMPLING LOCATION DESCRIPTION |          |                    | INITIAL SAMPLING RESULTS   |                  |                       | COMMENTS |
|-------------------------------|----------|--------------------|----------------------------|------------------|-----------------------|----------|
| SAMPLE ID                     | ROOM NO. | Outlet Description | Recommended Level = 20 ppb |                  |                       |          |
|                               |          |                    | First Draw (ppb)           | Retest Required? | Date Fixture Secured? |          |
| <b>SAMPLING DATE</b>          |          |                    | 10/15/2014                 |                  |                       |          |
| <b>RESULTS DATE</b>           |          |                    | 11/3/2014                  |                  |                       |          |
| PMRF-1318-K-K-FD              | 5        | Kitchen Sink       | 1.4                        | No               | N/A                   |          |
| PMRF-1318-AR-WFC-FD           | 1        | Water Fountain     | <0.5                       | No               | N/A                   |          |