

Priority Areas Lead Testing and Corrective Actions (OCT 2014)
 NCBC GULFPORT Youth Center
 Building 335

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb							Recommended Level = 20ppb	
			First Draw (ppb) [Enter non-detect/ numeric value]	Retest required? [Enter YES/NO]	Date Fixture Secured? (See Note 1) [Enter mm/dd/yyyy]	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]	Description	First Draw (ppb) (See note 2) [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]
SAMPLING DATE			10/4/2014			mm/dd/yyyy	10/25/2014				
RESULTS DATE			10/15/2014			mm/dd/yyyy	10/30/2014				
DRINKING	GPT-335-RM103-HALL-WFC-FD (BLDG-335-7)	Cooler fountain by game room in hallway	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	GPT-335-RM111-K-K-FD (BLDG-335-8)	Kitchen Food Prep sink	4	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	GPT-335-RM111-K-ICE-FD (BLDG-335-9)	Kitchen Ice machine	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GPT-335-RM123-BATH-HHW-A-FD (BLDG-335-1)	High hand wash sink Men's Bathroom	23	YES	N/A	N/A	19	non-detect	Routine Control Measures Only - Aerator Cleaning	N/A	N/A
WASHING	GPT-335-RM123-BATH-HHW-B-FD (BLDG-335-2)	High hand wash sink Men's Bathroom	7.8	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GPT-335-RM123-BATH-HHW-C-FD (BLDG-335-3)	High hand wash sink Men's Bathroom	2.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GPT-335-RM119-BATH-HHW-A-FD (BLDG-335-4)	High hand wash sink Women's Bathroom	2.8	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GPT-335-RM119-BATH-HHW-B-FD (BLDG-335-5)	High hand wash sink Women's Bathroom	6.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GPT-335-RM119-BATH-HHW-C-FD (BLDG-335-6)	High hand wash sink Women's Bathroom	3.8	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GPT-335-RM111-K-HHW-FD (BLDG-335-10)	Kitchen High hand wash sink	22	YES	N/A	N/A	3	non-detect	Routine Control Measures Only - Aerator Cleaning	N/A	N/A

Notes:

¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 20ppb.

² Post-remediation sampling was initially conducted on 10/25/2014. Additional routine control measures in the form of aerator cleaning were implemented and final results below recommended level of 20ppb for sample collected on 10/25/2014 are shown on the table.

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 20ppb				
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	1	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0

Priority Areas Lead Testing and Corrective Actions (OCT 2014)
 NCBC GULFPORT Youth Center
 Building 335

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS		RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb						Description	Recommended Level = 20ppb
			First Draw (ppb) [Enter non-detect/numeric value]	Retest required? [Enter YES/NO]	Date Fixture Secured? (See Note 1) [Enter mm/dd/yyyy]	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) [Enter non-detect/numeric value]	First Draw (ppb) [Enter non-detect/numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/numeric value]		First Draw (ppb) (See note 2) [Enter non-detect/numeric value]
SAMPLING DATE			10/4/2014			mm/dd/yyyy	10/25/2014			
RESULTS DATE			10/15/2014			mm/dd/yyyy	10/30/2014			
Total Cook/Brush		2	0			0	0		0	
Total Cook/Brush > 20 ppb		0	0			0	0		0	
Total Washing		7	0			2	0		0	
Total Washing > 20 ppb		2	0			0	0		0	
Total Samples		10	0			2	0		0	
Total Samples > 20 ppb		2	0			0	0		0	