

Priority Areas Lead Testing and Corrective Actions NOVEMBER 2014
NASJRB FORTH WORTH PLAY AREAS

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?	Recommended Level = 20ppb				Description	Recommended Level = 20ppb
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			10/15/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			10/27/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	FW-3334-PLAY-WFBA-FD (OPA-1)	Home plate sports complex by baseball fields Across from CDC, the taller fountain on the left	3.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	FW-3334-PLAY-WFBB-FD (OPA-2)	Home plate sports complex by baseball fields Across from CDC, the short fountain on the right	5.5	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Recommended Level = 20ppb			First Draw (ppb)
		Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	
Total Drinking	2	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	0	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	0	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	2	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0