

Priority Areas Lead Testing and Corrective Actions December 2014 through January 2015  
NS Guantanamo Bay MIDDLE and HIGH SCHOOL BLDG 2124

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb					
First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			12/6/2014 through 1/11/2015			mm/dd/yyyy	1/11/2015	1/11/2015		mm/dd/yyyy	
RESULTS DATE			12/24/2014 through 1/16/2015			mm/dd/yyyy	1/16/2015	1/16/2015		mm/dd/yyyy	
DRINKING	GTMO-2124-CWING-WFC-FD* (BLDG 2124-15)	C-Wing courtyard between electric closet and janitor closet	3.8	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	GTMO-2124-CWING-WFC-FD- 2 (BLDG 2124-15)	C-Wing courtyard between electric closet and janitor closet	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	GTMO-2124-DWING-WFC- FD* (BLDG 2124-30)	D-Wing cooler fountain between restrooms	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	GTMO-2124-DWING-WFC-FD- 2 (BLDG 2124-30)	D-Wing cooler fountain between restrooms	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	GTMO-2124-FWING-WFC-FD (BLDG 2124-38)	F-Wing - Cooler fountain in courtyard by soda machine and ice machine	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	GTMO-2124-FWING-BY GIRLS LOCKERROOM-WFC-FD* (BLDG 2124-42)	F-Wing - Water fountain in the courtyard on girl's locker room side	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	GTMO-2124-FWING-BY GIRLS LOCKERROOM-WFC-FD-2 (BLDG 2124-42)	Water fountain in F-Wing courtyard on girls locker room side	3.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	GTMO-2124-HALL-HHWC-FD* (BLDG 2124-44)	Water Fountain Cooler	3.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	GTMO-2124-AWING-WFC- 2FD-2 (BLDG 2124-44)	A-Wing water fountain	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-A12-BATH-GIRLS- HHWA-FD (BLDG 2124-1)	A-Wing - Girls restroom in A- Wing	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-A12-BATH-GIRLS- HHWB-FD (BLDG 2124-2)	A-Wing - Girls restroom in A- Wing	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions December 2014 through January 2015  
NS Guantanamo Bay MIDDLE and HIGH SCHOOL BLDG 2124

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb				Description	Recommended Level = 20ppb
First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
<b>SAMPLING DATE</b>			12/6/2014 through 1/11/2015			mm/dd/yyyy	1/11/2015	1/11/2015		mm/dd/yyyy	
<b>RESULTS DATE</b>			12/24/2014 through 1/16/2015			mm/dd/yyyy	1/16/2015	1/16/2015		mm/dd/yyyy	
WASHING	GTMO-2124-A11-BATH-BOYS-HHWA-FD (BLDG 2124-3)	A-Wing - Boys restroom in A-Wing	1.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-A11-BATH-BOYS-HHWA-FD (BLDG 2124-4)	A-Wing - Boys restroom in A-Wing	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-B18-BATH-BOYS-HHW-FD (BLDG 2124-5)	B-Wing - Administrative Building	1.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-B19-BATH-GIRLS-HHW-FD (BLDG 2124-6)	B-Wing - Administrative Building	3.1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-B17-LOUNGE-HHW-FD (BLDG 2124-7)	B-Wing - Administrative Building	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-B3-RM-HHW-FD (BLDG 2124-8)	B-Wing - Administrative Building	5.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-B21-RM-HHW-FD (BLDG 2124-9)	B-Wing - Room between rooms B20 and B23	10	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-C4-BATH-BOYS-HHWA-FD (BLDG 2124-10)	C-Wing - Boys restroom in C-Wing	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-C4-BATH-BOYS-HHWA-FD (BLDG 2124-11)	C-Wing - Boys restroom in C-Wing	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-C1-BATH-GIRLS-HHWA-FD (BLDG 2124-12)	C-Wing - Girls restroom in C-Wing	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-C1-BATH-GIRLS-HHWA-FD (BLDG 2124-13)	C-Wing - Girls restroom in C-Wing	2	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-C5A-NURSE-HHW-FD (BLDG 2124-14)	C-Wing - Nurse's Office	3.1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-C10-RM-STATION 1-HHWA-FD (BLDG 2124-16)	C-Wing - Jet Nozzle Chemistry classroom	160	YES	N/A	N/A	91	non-detect	Taken Out of Service	N/A	N/A

Priority Areas Lead Testing and Corrective Actions December 2014 through January 2015  
NS Guantanamo Bay MIDDLE and HIGH SCHOOL BLDG 2124

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb				Description	Recommended Level = 20ppb
First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
<b>SAMPLING DATE</b>			12/6/2014 through 1/11/2015			mm/dd/yyyy	1/11/2015	1/11/2015		mm/dd/yyyy	
<b>RESULTS DATE</b>			12/24/2014 through 1/16/2015			mm/dd/yyyy	1/16/2015	1/16/2015		mm/dd/yyyy	
WASHING	GTMO-2124-C10-RM-STATION 1-HHWW-FD (BLDG 2124-17)	C-Wing Chemistry Classroom - Standard faucet	16	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-C10-RM-STATION 2-HHWA-FD (BLDG 2124-18)	C-Wing Chemistry Classroom - Jet Nozzle	12	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-C10-RM-STATION 2-HHWW-FD (BLDG 2124-19)	C-Wing Chemistry Classroom - Standard faucet	140	YES	N/A	N/A	63	non-detect	Taken Out of Service	N/A	N/A
WASHING	GTMO-2124-C10-RM-STATION 3-HHWA-FD (BLDG 2124-20)	C-Wing Chemistry Classroom - Jet Nozzle	10	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-C10-RM-STATION 3-HHWW-FD (BLDG 2124-21)	C-Wing Chemistry Classroom - Standard faucet	11	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-C10-RM-STATION 4-HHWA-FD (BLDG 2124-22)	C-Wing Chemistry Classroom - Jet Nozzle	17	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-C10-RM-STATION 4-HHWW-FD (BLDG 2124-23)	C-Wing Chemistry Classroom - Standard faucet	19	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-C10-RM-STATION 5-HHWA-FD (BLDG 2124-24)	C-Wing Chemistry Classroom - Jet Nozzle	82	YES	N/A	N/A	13	non-detect	Routine Control Measures Only	N/A	N/A
WASHING	GTMO-2124-C10-RM-STATION 5-HHWW-FD (BLDG 2124-25)	C-Wing Chemistry Classroom - Standard faucet	20	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-C10-RM-STATION 6-HHWA-FD (BLDG 2124-26)	C-Wing Chemistry Classroom - Jet Nozzle	6	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-C10-RM-STATION 6-HHWW-FD (BLDG 2124-27)	C-Wing Chemistry Classroom - Standard faucet	63	YES	N/A	N/A	43	non-detect	Taken Out of Service	N/A	N/A
WASHING	GTMO-2124-C12-RM--HHW-FD (BLDG 2124-28)	C-Wing - Science Classroom	9.4	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions December 2014 through January 2015  
NS Guantanamo Bay MIDDLE and HIGH SCHOOL BLDG 2124

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)		Recommended Level = 20ppb	
Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)							Description	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
<b>SAMPLING DATE</b>			12/6/2014 through 1/11/2015			mm/dd/yyyy	1/11/2015	1/11/2015		mm/dd/yyyy	
<b>RESULTS DATE</b>			12/24/2014 through 1/16/2015			mm/dd/yyyy	1/16/2015	1/16/2015		mm/dd/yyyy	
WASHING	GTMO-2124-D2-BATH-GIRLS-HHW-FD (BLDG 2124-29)	D-Wing - Girls restroom in D-Wing	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-D1-BATH-BOYS-HHW-FD (BLDG 2124-31)	D-Wing - Boys restroom in D-Wing	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-D10-RM--HHWA-FD (BLDG 2124-32)	D-Wing - Art Classroom	1.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-D10-RM--HHWB-FD (BLDG 2124-33)	D-Wing - Art Classroom	2.1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-E10-BATH-BOYS-HHWA-FD (BLDG 2124-34)	E-Wing - Boys restroom in gym	4.8	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-E10-BATH-BOYS-HHWA-FD (BLDG 2124-35)	E-Wing - Boys restroom in gym	4.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-E10-BATH-GIRLS-HHWA-FD (BLDG 2124-36)	E-Wing - Girls restroom in gym	5.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-E10-BATH-GIRLS-HHWA-FD (BLDG 2124-37)	E-Wing - Girls restroom in gym	7.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-F14-BATH-BOYS-HHW-FD (BLDG 2124-40)	F-Wing - Sink in boys locker room	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-F7-BATH-GIRLS-HHW-FD (BLDG 2124-41)	Sink in girls locker room - F-Wing	1.8	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	GTMO-2124-D10-RM-HHWC-FD (BLDG 2124-43)	Wash sink - Art Room	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:  
<sup>1</sup> Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 20ppb.  
<sup>2</sup> Post-remediation sampling not necessary as outlets were disconnected from water supply and taken out of service  
 \*Outlet was replaced after initial sampling event and resampled in JAN 2015.

Priority Areas Lead Testing and Corrective Actions December 2014 through January 2015  
NS Guantanamo Bay MIDDLE and HIGH SCHOOL BLDG 2124

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 20ppb				
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	9	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	0	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	38	0	4	4	0
Total Washing > 20 ppb	4	0	3	0	0
Total Samples	47	0	4	4	0
Total Samples > 20 ppb	4	0	3	0	0