

Priority Areas Lead Testing and Corrective Actions December 2014
NS Guantanamo Bay TEEN CENTER BLDG 692

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb				Description	Recommended Level = 20ppb
First Draw (ppb)	Retest required?	Date Fixture Secured?				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			12/7/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		
RESULTS DATE			12/17/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		
WASHING	GTMO-692-RM-HHW-FD (BLDG 692-1)	Sink in general area.	non-detect	NO	N/A	N/A	N/A	N/A	N/A	N/A	

Notes:

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	0	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	0	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	1	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	1	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0