

Priority Areas Lead Testing and Corrective Actions November 2014
NAS MERIDIAN Youth Center Building 994

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS			
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?		Recommended Level = 20ppb			First Draw (ppb)
Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)							First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	
SAMPLING DATE			11/13/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy				mm/dd/yyyy	
RESULTS DATE			11/21/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy				mm/dd/yyyy	
DRINKING	MER-994-HALL-WFC-FD (BLDG 994-1)	Water Fountain by entrance/lobby	non-detect	NO	N/A	N/A	N/A	N/A				N/A	N/A
COOKING	MER-994-K-K-FD (BLDG 994-2)	Kitchen sink behind reception desk	1.8	NO	N/A	N/A	N/A	N/A				N/A	N/A
WASHING	MER-994-BATH-MENS-HHWA (BLDG 994-3)	Men's Restroom Sink on left	non-detect	NO	N/A	N/A	N/A	N/A				N/A	N/A
WASHING	MER-994-BATH-MENS-HHWA (BLDG 994-4)	Men's Restroom Sink on right	non-detect	NO	N/A	N/A	N/A	N/A				N/A	N/A
WASHING	MER-994-BATH-WOMENS-HHWA (BLDG 994-5)	Women's Restroom Sink on left	non-detect	NO	N/A	N/A	N/A	N/A				N/A	N/A
WASHING	MER-994-BATH-WOMENS-HHWA (BLDG 994-6)	Women's Restroom Sink on right	non-detect	NO	N/A	N/A	N/A	N/A				N/A	N/A

Notes:

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Recommended Level = 20ppb			First Draw (ppb)
		Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	
Total Drinking	1	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	1	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	4	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	6	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0