

Priority Areas Lead Testing and Corrective Actions NOVEMBER 2014
 NAVAL STATION MAYPORT Teen Center
 Building 1326

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?	Recommended Level = 20ppb				Description	First Draw (ppb)
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)			
SAMPLING DATE			10/11/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			10/17/2014			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	MYP-1326-HALL-WFC-FD (BLDG 1326-1)	water fountain located in hallway below the "Information Center Bulletin Board"	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	MYP-1326-K-K-FD (BLDG 1326-6)	Kitchen	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-1326-WBATH-LHW-FD (BLDG 1326-2)	Women's Bathroom Left sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-1326-WBATH-HHW-FD (BLDG 1326-3)	Women's Bathroom Right sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-1326-MBATH-LHW-FD (BLDG 1326-4)	Men's Bathroom Left sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MYP-1326-MBATH-HHW-FD (BLDG 1326-5)	Men's Bathroom Right sink	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	1	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	1	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	4	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	6	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0